

# ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)  
 (An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)  
 Website: www.itslab.in, Email: itlrclab@gmail.com, info@itslab.in, contact@itslab.in  
 +91 9911659800, 9305780312, 09958849764



Doc. No. – ITS/7.8-01, Page No. – 1 of 1

## TEST REPORT

### Water Sample Analysis

Report Code-W-280226-12

Issue Date: 03/03/2026

Issued To: THE MANTHAN SCHOOL

Plot No. – GH – 04, Sector – 16 C, Greater Noida, (U.P.), India

#### SAMPLING & ANALYSIS DATA

Sample Description	:	Drinking Water Sample
Source of Water	:	R.O. Water
Sample Location	:	A Block –3 <sup>rd</sup> Floor
Sample Drawn On	:	28/02/2026
Sample Drawn By	:	Mr. Vivek Kumar (ITS LAB Representative)
Sampling Plan & Procedure	:	IS:17614 (Part-1):2021
Sample Quantity	:	2.0 Liter in Pet Bottle & 500 ml Glass Sterilized Bottle
Weather Condition	:	Clear
Sample Received On	:	28/02/2026
Analysis Duration	:	28/02/2026 To 03/03/2026
Test Specification To Be Used	:	IS:10500:2012

#### ANALYSIS TEST RESULTS

Chemical Analysis					
S. No.	Parameter	Test Method	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH Value @ 25°C	IS:3025(Part-11)	7.05	6.5 – 8.5	-
2.	Colour (Hazen)	IS:3025(Part-04)	< 5	5	15
3.	Odour	IS:3025(Part-05)	Agreeable	Agreeable	Agreeable
4.	Taste	IS:3025(Part-08)	Agreeable	Agreeable	-
5.	Turbidity (NTU)	IS:3025(Part-10)	< 1	1	5
6.	Total Hardness (as CaCO <sub>3</sub> ) (mg/l)	IS:3025(Part-21)	24.0	200	600
7.	Chloride(as Cl) (mg/l)	IS:3025(Part-32)	18.0	250	1000
8.	Calcium (as Ca) (mg/l)	IS:3025(Part-40)	5.6	75	200
9.	Total Iron (as Fe) (mg/l)	IS:3025(Part-53)	<0.05	1.0	-
10.	Nitrate (as NO <sub>3</sub> )	IS:3025(Part-34)	<0.1	45	No Relaxation
11.	Total Dissolved Solid (TDS) (mg/l)	IS:3025(Part-16)	102	500	2000
12.	Alkalinity (as CaCO <sub>3</sub> ) (mg/l)	IS:3025(Part-23)	48.0	200	600
13.	Fluoride (as F) (mg/l)	IS:3025(Part-60)	<0.1	1.0	1.5
14.	Sulphate (as SO <sub>4</sub> ) (mg/l)	IS:3025(Part-24)	<1.0	200	400
15.	Magnesium (as Mg) (mg/l)	IS:3025(Part-46)	2.43	30	100

#### Microbiological Analysis


#### RESULTS

S.No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1.	Escherichia coli	IS-15185:2016	Absent	Absent/100ml
2.	Coliform Bacteria	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.

Hence water is fit for Drinking purpose

Note: - Report shall not be produce except in full without approval of the laboratory

  
 Reviewed by  
 Babita Darwal  
 (Microbiologist)



\*\*\*End of Report\*\*\*

#### Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.